



UPS
NON COUPE

Longueur des cables:
 Alim. MGC = 2.3m
 Ventilation REM = 4m
 Ventilation RPM = 8m
 Thermostat REM = 3.25m
 Thermostat RPM = 3.25m

Ventilation RPM, REM fonctionne si t > 10deg.

R	Observations : ventil_REM_RPM.sch	Appareil No:	A3	
C	Modifications:	Sheet No:		
L	VENTILATION	Ech.	Dessine	O.Genevay
D	ARMOIRE REM ET RPM		Date	11.12.1997
Q	T4	Page	Etude	E.Ischi
.		./.	Revise	20 10.2000
.	OBSERVATOIRE DE GENEVE	T4		
.	Tel.(022) 755 26 11 / Fax.(022) 755 39 83			